

NOTICE OF DECISION
ZONING BOARD OF ADJUSTMENT
TOWN OF HOLDERNESS
PO BOX 203
HOLDERNESS, NH 03245

Case No: 369-08-13

You are hereby notified that the appeal for a Variance request to allow for the installation of a new septic system for property located at 69 Shepherd Hill Road, Tax Map 102 Lot 35, in the Residential District, has been GRANTED with the following determination:

1. The leach field shall be no closer than ten (10) feet wide to the side property line; and
2. The septic tank shall be no closer than ten (10) feet to the side property line; and
3. The septic tank shall be no closer than 100' to the on site well.

Susan Webster, Chair
Board of Adjustment

August 14, 2013

Note: Any person affected has a right to appeal this decision. If you wish to appeal, you must act within thirty days of the date of this notice, tomorrow being day one. The necessary first step, before any appeal may be taken to the courts, is to apply to the Board of Adjustment for a rehearing. The motion for rehearing must set forth all the grounds on which you will base your appeal. See New Hampshire Revised Statutes Annotated, Chapter 677 for details.